

Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Berzovia-Cererea de apa

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043		
Sistemul de alimentare cu apa BERZOVIA	Populatie totala in aria de deservire		cap	3003	2975	2947	2919	2891	2864	2837	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522	2485	2448	2413	2377	2342	2308	2274	2241	2208	2176	2144	2112	2081	
	CONSUM CASNIC																																			
	RURAL	Total populatie rurala	nr.	3003	2975	2947	2919	2891	2864	2837	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522	2485	2448	2413	2377	2342	2308	2274	2241	2208	2176	2144	2112	2081	
		Populatie rurala conectata	nr.	0	425	842	1251	1652	2046	2432	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522	2485	2448	2413	2377	2342	2308	2274	2241	2208	2176	2144	2112	2081	
		Grad de bransare	%	0.00	14.29	28.57	42.86	57.14	71.43	85.71	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific rural	l/om,zi	0.00	71.97	71.87	72.09	72.75	73.37	73.94	74.51	75.05	75.57	76.11	76.64	77.18	77.73	78.27	78.82	79.38	79.94	80.50	81.07	81.64	82.21	82.79	83.37	83.96	84.55	85.15	85.75	86.35	86.96	87.57	88.19	
		Qzi med rural	l/s	0.00	0.35	0.70	1.04	1.39	1.74	2.08	2.42	2.42	2.41	2.40	2.40	2.39	2.38	2.38	2.37	2.36	2.35	2.33	2.31	2.30	2.28	2.26	2.24	2.23	2.21	2.19	2.17	2.16	2.14	2.12		
		Qzi max rural	l/s	0.00	0.57	1.12	1.67	2.23	2.78	3.33	3.88	3.87	3.86	3.85	3.84	3.82	3.81	3.80	3.79	3.78	3.77	3.76	3.73	3.70	3.67	3.64	3.62	3.59	3.56	3.53	3.51	3.48	3.45	3.43	3.40	
		Qor max rural	l/s	0.00	1.53	3.03	4.51	6.01	7.50	8.99	10.47	10.44	10.41	10.38	10.35	10.32	10.30	10.27	10.24	10.21	10.18	10.15	10.07	9.99	9.92	9.84	9.76	9.69	9.61	9.54	9.47	9.39	9.32	9.25	9.18	
		CONSUM NONCASNIC																																		
	RURAL	Total bransamente	nr.	0	5	10	15	20	26	31	36	36	37	37	38	38	38	39	39	40	40	41	41	42	42	43	43	44	44	45	45	46	46	46		
		Bransamente - Institutii	nr.	0	1	2	4	5	6	7	9	9	9	9	9	9	9	9	9	9	10	10	10	10	10	10	10	10	11	11	11	11	11	11	11	
		Bransamente - Companii	nr.	0	4	8	12	16	19	23	27	27	28	28	28	29	29	30	30	30	31	31	31	31	32	32	33	33	33	34	34	34	35	35	35	
		Grad de bransare	%	0.00	14.29	28.57	42.86	57.14	71.43	85.71	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific - INSTITUTII	l/bransament,zi	0.00	2976.28	2991.37	2946.56	2934.77	2923.03	2911.34	2899.70	2891.00	2882.32	2873.68	2865.06	2856.46	2847.89	2839.35	2830.83	2822.34	2813.87	2805.43	2797.01	2788.62	2780.26	2771.91	2763.60	2755.31	2747.04	2738.80	2730.58	2722.39	2714.23	2706.08	2697.97	
		Qzi med rural	l/s	0.00	0.04	0.08	0.13	0.17	0.21	0.25	0.29	0.29	0.29	0.29	0.30	0.30	0.31	0.31	0.31	0.31	0.32	0.32	0.32	0.32	0.33	0.33	0.33	0.34	0.34	0.34	0.34	0.34	0.34	0.35	0.35	
		Qzi max rural	l/s	0.00	0.07	0.13	0.20	0.27	0.33	0.40	0.46	0.47	0.47	0.47	0.48	0.48	0.49	0.49	0.50	0.50	0.51	0.51	0.52	0.52	0.52	0.53	0.53	0.54	0.54	0.55	0.55	0.55	0.56	0.56		
		Qor max rural	l/s	0.00	0.18	0.36	0.54	0.72	0.90	1.07	1.24	1.26	1.27	1.28	1.29	1.30	1.31	1.32	1.34	1.35	1.36	1.37	1.38	1.39	1.40	1.41	1.42	1.43	1.44	1.45	1.46	1.47	1.48	1.49	1.50	
		Consum specific - COMPANII	l/bransament,zi	0.00	1625.39	1622.14	1618.90	1620.52	1622.14	1623.78	1625.39	1627.01	1628.64	1630.27	1631.90	1633.53	1635.18	1636.80	1638.43	1640.07	1641.71	1643.35	1645.00	1646.64	1648.29	1649.94	1651.59	1653.24	1654.89	1656.55	1658.20	1659.86	1661.52	1663.18	1664.85	
		Qzi med rural	l/s	0.00	0.07	0.15	0.22	0.29	0.36	0.44	0.51	0.52	0.52	0.53	0.54	0.55	0.56	0.57	0.58	0.59	0.60	0.61	0.62	0.62	0.63	0.64	0.64	0.65	0.66	0.67	0.67	0.68	0.68			
		Qzi max rural	l/s	0.00	0.12	0.23	0.35	0.47	0.58	0.70	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	0.94	0.95	0.96	0.97	0.98	1.00	1.01	1.02	1.03	1.04	1.05	1.06	1.08	1.09	
		Qor max rural	l/s	0.00	0.31	0.63	0.94	1.26	1.57	1.89	2.20	2.23	2.26	2.29	2.32	2.35	2.38	2.41	2.44	2.48	2.51	2.54	2.57	2.60	2.63	2.66	2.69	2.72	2.75	2.78	2.81	2.84	2.87	2.90	2.94	
	Total general		3003	2975	2947	2919	2891	2864	2837	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522	2485	2448	2413	2377	2342	2308	2274	2241	2208	2176	2144	2112	2081		
	BERZOVIA		procent %	3003	2975	2947	2919	2891	2864	2837	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522	2485	2448	2413	2377	2342	2308	2274	2241	2208	2176	2144	2112	2081	
	Berzovia		67.53	2028	2009	1990	1971	1953	1934	1916	1898	1880	1861	1843	1825	1807	1789	1772	1754	1737	1720	1703	1678	1653	1629	1605	1582	1559	1536	1513	1491	1469	1448	1426	1405	
	Gheretis		32.47	975	966	957	948	939	930	921	913	904	895	886	878	869	860	852	844	835	827	819	807	795	783	772	761	749	738	728	717	706	696	686	676	
	CONSUMUL DE APA		mc/zi	0.00	40.54	80.35	119.85	159.72	199.45	238.99	278.37	278.72	278.95	279.19	279.43	279.66	279.90	280.15	280.39	280.63	280.88	281.12	280.38	279.65	278.93	278.22	277.53	276.85	276.17	275.51	274.86	274.22	273.60	272.98	272.37	
	Q zi maxim		mc/zi	0.00	64.86	128.56	191.77	255.55	319.12	382.38	445.40	445.95	446.33	446.70	447.08	447.46	447.85	448.23	448.62	449.01	449.40	449.79	448.61	447.44	446.29	445.16	444.05	442.95	441.88	440.82	439.78	438.76	437.75	436.76	435.79	
	Q orar maxim		mc/h	0.00	7.30	14.46	21.57	28.75	35.90	43.01	50.10	50.16	50.21	50.25	50.29	50.33	50.38	50.42	50.46	50.51	50.55	50.60	50.46	50.33	50.20	50.07	49.95	49.83	49.70	49.59	49.47	49.35	49.24	49.13	49.02	
	Q specific casnic		l/om,zi	0.00	0.00	0.00	72.09	72.75	73.37	73.94	74.51	75.05	75.57	76.11	76.64	77.18	77.73	78.27	78.82	79.38	79.94	80.50	81.07	81.64	82.21	82.79	83.37	83.96	84.55	85.15	85.75	86.35	86.96	87.57	88.19	
Q specific noncasnic		l/bransament,zi	0.00	0.00	0.00	1937.89	1936.29	1934.70	1933.12	1931.56	1930.70	1929.85	1929.01	1928.18	1927.35	1926.54	1925.73	1924.92	1924.13	1923.34	1922.56	1921.78	1921.02	1920.26	1919.51	1918.76	1918.03	1917.30	1916.57	1915.86	1915.15	1914.45	1913.75	1913.07		
PIERDERI DE APA		mc/an	0.00	2611.19	5253.87	7954.75	10758.28	13631.99	16572.09	19581.62	19885.78	20184.01	20484.12	20786.11	21090.00	21395.81	21703.56	22013.26	22324.93	22638.59	22954.26	23190.17	23426.91	23664.49	23902.95	24142.31	24382.61	24623.87	24866.12	25109.40	25353.73	25599.14	25845.66	26093.33		
Q zi mediu		mc/zi	0.00	0.00	0.00	15.39	15.58	15.77	15.97	16.16	16.35	16.54	16.74	16.93	17.12	17.32	17.51	17.70	17.90	18.09	18.28	18.47	18.67	18.86	19.05	19.25	19.44	19.63	19.83	20.02	20.21	20.40	20.60	20.79		
Q zi maxim		mc/zi	0.00	47.69	94.74	141.65	189.20	236.80	284.39	332.02	333.20	334.25	335.31	336.37	337.45	338.52	339.61	340.70	341.79	342.90	344.01	343.91	343.83	343.77	343.71	343.67	343.65	343.64	343.66	343.69	343.73	343.79	343.86			
Q orar maxim		mc/h	0.00	72.02	142.95	213.56	285.03	356.47	427.78	499.05	500.43	501.62	502.82	504.03	505.24	506.47	507.69	508.93	510.17	511.42	512.68	513.94	515.21	516.48	517.75	519.02	520.29	521.56	522.83	524.10	525.37	526.64	527.91			

ANUL		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043
Pierderi de apa Berzovia	Populatie conectata	no.	0	425	842	1251	1652	2046	2432	2810	2784	2756	2729	2702	2676	2649	2623	2598	2572	2547	2522												