

Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Carnecea-Cererea de apa

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043		
Sistemul de alimentare cu apa CARNECEA	Populatie totala in aria de deservire		cap	367	364	360	357	353	350	347	343	340	337	334	330	327	324	321	318	314	311	308	304	299	295	291	286	282	278	274	270	266	262	258	254	
	CONSUM CASNIC																																			
	RURAL	Total populatie rurala		nr.	367	364	360	357	353	350	347	343	340	337	334	330	327	324	321	318	314	311	308	304	299	295	291	286	282	278	274	270	266	262	258	254
		Populatie rurala conectata		nr.	0	0	0	54	128	201	273	343	340	337	334	330	327	324	321	318	314	311	308	304	299	295	291	286	282	278	274	270	266	262	258	254
		Grad de bransare		%	0.00	0.00	0.00	15.00	36.25	57.50	78.75	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific rural		l/om,zi	0.00	0.00	0.00	68.36	66.97	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
		Qzi med rural		l/s	0.00	0.00	0.00	0.04	0.10	0.16	0.22	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.26	0.26	0.26	0.26	0.25	0.25	0.25	0.25	0.25	0.24	0.24	0.24	0.24
		Qzi max rural		l/s	0.00	0.00	0.00	0.07	0.16	0.25	0.34	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.42	0.42	0.42	0.42	0.42	0.41	0.41	0.41	0.40	0.40	0.40	0.39	0.39	0.38	0.38	0.38
		Qor max rural		l/s	0.00	0.00	0.00	0.19	0.47	0.74	1.01	1.29	1.28	1.28	1.28	1.28	1.27	1.27	1.26	1.26	1.26	1.25	1.25	1.25	1.24	1.23	1.22	1.21	1.20	1.19	1.18	1.17	1.16	1.15	1.15	1.14
	RURAL	CONSUM NONCASNIC																																		
		Total bransamente		nr.	0	0	0	1	2	3	4	4	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6
		Bransamente - Institutii		nr.	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
		Bransamente - Companii		nr.	0	0	0	1	1	2	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	4	4	4	4	4	4	4	4	4	4
		Grad de bransare		%	0.00	0.00	0.00	25.00	43.75	62.50	81.25	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific - INSTITUTII		l/bransament,zi	0.00	0.00	0.00	1130.11	1125.59	1121.09	1116.60	1112.14	1108.80	1105.47	1102.16	1098.85	1095.55	1092.27	1088.99	1085.72	1082.47	1079.22	1075.98	1072.75	1069.54	1066.33	1063.13	1059.94	1056.76	1053.59	1050.43	1047.28	1044.13	1041.00	1037.88	1034.77
		Qzi med rural		l/s	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
		Qzi max rural		l/s	0.00	0.00	0.00	0.01	0.01	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
		Qor max rural		l/s	0.00	0.00	0.00	0.02	0.04	0.05	0.07	0.08	0.08	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
		Consum specific - COMPANII		l/bransament,zi	0.00	0.00	0.00	952.30	953.25	954.21	955.16	956.11	957.07	958.03	958.99	959.95	960.91	961.87	962.83	963.79	964.75	965.72	966.68	967.65	968.62	969.59	970.56	971.53	972.50	973.47	974.45	975.42	976.40	977.37	978.35	979.33
		Qzi med rural		l/s	0.00	0.00	0.00	0.01	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Qzi max rural		l/s	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07		
Qor max rural		l/s	0.00	0.00	0.00	0.04	0.07	0.10	0.13	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.18	0.18	0.18	0.18	0.18	0.18	0.19	0.19	0.19	0.19	0.19	0.19	0.20	0.20	0.20	0.20	0.20		
CARNECEA	Total general		367	364	360	357	353	350	347	343	340	337	334	330	327	324	321	318	314	311	308	304	299	295	291	286	282	278	274	270	266	262	258	254		
	Carnecea		367	364	360	357	353	350	347	343	340	337	334	330	327	324	321	318	314	311	308	304	299	295	291	286	282	278	274	270	266	262	258	254		

ANUL		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	
CONSUMUL DE APA	Q zi mediu	mc/zi	0.00	0.00	0.00	4.68	10.56	16.42	22.26	28.07	28.06	28.04	28.02	27.99	27.97	27.95	27.93	27.90	27.88	27.86	27.84	27.81	27.78	27.75	27.72	27.69	27.66	27.63	27.60	27.57	27.54	27.51	27.48	
	Q zi maxim	mc/zi	0.00	0.00	0.00	7.45	16.81	26.13	35.43	44.68	44.67	44.63	44.59	44.56	44.52	44.49	44.45	44.42	44.38	44.35	44.31	44.27	44.23	44.19	44.15	44.11	44.07	44.03	43.99	43.95	43.91	43.87	43.83	
	Q orar maxim	mc/h	0.00	0.00	0.00	0.92	2.08	3.23	4.37	5.52	5.51	5.51	5.51	5.50	5.49	5.49	5.48	5.48	5.47	5.47	5.46	5.45	5.44	5.43	5.42	5.41	5.40	5.39	5.38	5.37	5.36	5.35	5.34	
	Q specific casnic	l/om,zi	0.00	0.00	0.00	66.36	66.97	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
PIERDERI DE APA	Q specific noncasnic	l/bransament,zi	0.00	0.00	0.00	1006.63	1005.91	1005.20	1004.49	1003.79	1003.57	1003.35	1003.12	1002.88	1002.64	1002.39	1002.14	1001.88	1001.62	1001.35	1001.08	1000.80	1000.53	1000.24	999.96	999.67	999.37	999.08	998.78	998.48	998.18	997.87	997.57	997.22
	mc/an	0.00	0.00	0.00	301.66	686.12	1076.41	1471.88	1872.65	1888.16	1902.86	1917.59	1930.47	1943.37	1956.29	1969.23	1982.20	1995.19	2008.20	2021.23	2034.29	2047.36	2060.43	2073.51	2086.60	2099.70	2112.81	2125.93	2139.06	2152.20	2165.35	2178.51	2191.68	2204.86
CERINTA DE APA	%	0.00	0.00	0.00	15.00	15.11	15.23	15.34	15.45	15.57	15.68	15.79	15.89	15.99	16.09	16.19	16.29	16.39	16.49	16.59	16.69	16.79	16.89	16.99	17.09	17.19	17.29	17.39	17.49	17.59	17.69	17.79	17.89	
	Q zi mediu	mc/zi	0.00	0.00	0.00	5.51	12.44	19.37	26.29	33.20	33.24	33.25	33.27	33.28	33.30	33.31	33.32	33.34	33.35	33.36	33.37	33.38	33.39	33.40	33.41	33.42	33.43	33.44	33.45	33.46	33.47	33.48	33.49	
	Q zi maxim	mc/zi	0.00	0.00	0.00	8.28	18.69	29.08	39.46	49.81	49.84	49.84	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85	49.85
	Q orar maxim	mc/h	0.00	0.00	0.00	0.95	2.15	3.35	4.54	5.73	5.73	5.73	5.72	5.72	5.72	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71	5.71

