

Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Secaseni-Cererea de apa

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	
Sistemul de alimentare cu apa SECASENI	Populatie totala in aria de deservire	cap	404	400	396	392	389	385	381	378	374	370	367	363	360	356	353	349	346	342	339	334	329	324	320	315	310	306	301	297	292	288	284	280	
	CONSUM CASNIC																																		
	RURAL	Total populatie rurala	nr.	404	400	396	392	389	385	381	378	374	370	367	363	360	356	353	349	346	342	339	334	329	324	320	315	310	306	301	297	292	288	284	280
		Populatie rurala conectata	nr.	0	0	0	59	141	221	300	378	374	370	367	363	360	356	353	349	346	342	339	334	329	324	320	315	310	306	301	297	292	288	284	280
		Grad de bransare	%	0.00	0.00	0.00	15.00	36.25	57.50	78.75	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific rural	l/om,zi	0.00	0.00	0.00	66.36	66.97	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
		Qzi med rural	l/s	0.00	0.00	0.00	0.05	0.11	0.17	0.24	0.30	0.30	0.30	0.30	0.30	0.30	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.28	0.28	0.28	0.28	0.28	0.27	0.27	0.27	0.27	0.26	0.26
		Qzi max rural	l/s	0.00	0.00	0.00	0.07	0.17	0.28	0.38	0.48	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.46	0.46	0.46	0.46	0.45	0.45	0.44	0.44	0.43	0.43	0.43	0.42	0.42	0.42
	Qor max rural	l/s	0.00	0.00	0.00	0.21	0.51	0.82	1.11	1.41	1.41	1.41	1.41	1.40	1.40	1.39	1.39	1.39	1.38	1.38	1.37	1.37	1.36	1.35	1.34	1.33	1.32	1.31	1.30	1.29	1.28	1.27	1.26	1.25	1.24
	CONSUM NONCASNIC																																		
	RURAL	Total bransamente	nr.	0	0	0	1	2	3	3	4	4	4	4	4	4	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
		Bransamente - Institutii	nr.	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
		Bransamente - Companii	nr.	0	0	0	1	2	2	3	3	3	3	3	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
		Grad de bransare	%	0.00	0.00	0.00	25.00	43.75	62.50	81.25	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific - INSTITUTII	l/bransament,zi	0.00	0.00	0.00	1011.21	1007.17	1003.14	999.12	995.13	992.14	989.17	986.20	983.24	980.29	977.35	974.42	971.49	968.58	965.67	962.78	959.89	957.01	954.14	951.28	948.42	945.58	942.74	939.91	937.09	934.28	931.48	928.68	925.90
Qzi med rural		l/s	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Qzi max rural		l/s	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Qor max rural		l/s	0.00	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06
Consum specific - COMPANII		l/bransament,zi	0.00	0.00	0.00	968.21	969.18	970.15	971.12	972.09	973.06	974.03	975.01	976.00	977.00	978.01	979.02	980.03	981.05	982.07	983.09	984.11	985.13	986.15	987.17	988.19	989.21	990.23	991.25	992.27	993.29	994.31	995.33	996.35	
Qzi med rural		l/s	0.00	0.00	0.00	0.01	0.02	0.02	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
Qzi max rural	l/s	0.00	0.00	0.00	0.02	0.03	0.04	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.08	0.08	
Qor max rural	l/s	0.00	0.00	0.00	0.05	0.08	0.11	0.15	0.18	0.18	0.19	0.19	0.19	0.19	0.19	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.21	0.21	0.21	0.21	0.21	0.22	0.22	0.22	0.22	0.22	0.22	0.22	
Total general			404	400	396	392	389	385	381	378	374	370	367	363	360	356	353	349	346	342	339	334	329	324	320	315	310	306	301	297	292	288	284	280	
Secaseni		procent %	100.00																																

ANUL		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	
CONSUMUL DE APA	Q zi mediu	mc/zi	0.00	0.00	0.00	4.95	11.26	17.56	23.83	30.08	30.06	30.03	30.00	29.96	29.93	29.90	29.87	29.84	29.80	29.77	29.74	29.59	29.44	29.29	29.14	28.99	28.84	28.70	28.56	28.42	28.28	28.14	28.00	27.82
	Q zi maxim	mc/zi	0.00	0.00	0.00	7.88	17.92	27.95	37.93	47.88	47.85	47.80	47.75	47.69	47.64	47.59	47.54	47.49	47.44	47.39	47.34	47.10	46.85	46.62	46.38	46.14	45.91	45.68	45.45	45.23	45.01	44.79	44.57	44.29
	Q orar maxim	mc/h	0.00	0.00	0.00	0.97	2.21	3.45	4.68	5.90	5.90	5.89	5.88	5.87	5.86	5.85	5.84	5.84	5.81	5.78	5.75	5.72	5.69	5.66	5.63	5.61	5.58	5.55	5.52	5.50	5.50	5.50	5.46	
	Q specific casnic	l/om,zi	0.00	0.00	0.00	66.36	66.97	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
	Q specific noncasnic	l/bransament,zi	0.00	0.00	0.00	976.66	976.64	976.63	976.62	976.61	976.62	977.03	977.23	977.43	977.62	977.82	978.01	978.20	978.39	978.57	978.76	978.94	979.12	979.30	979.48	979.66	979.83	980.01	980.18	980.36	980.53	980.70	980.87	981.08
PIERDERI DE APA	mc/an	0.00	0.00	0.00	318.79	731.79	1151.09	1576.02	2006.68	2022.75	2037.92	2053.12	2066.33	2079.56	2092.80	2106.07	2119.35	2132.66	2146.00	2159.35	2172.70	2186.05	2199.40	2212.75	2226.10	2239.45	2252.80	2266.15	2279.50	2292.85	2306.20	2319.55	2332.90	2346.25
	%	0.00	0.00	0.00	15.00	15.11	15.23	15.34	15.45	15.57	15.68	15.79	15.89	15.99	16.09	16.19	16.29	16.39	16.49	16.59	16.69	16.79	16.89	16.99	17.09	17.19	17.29	17.39	17.49	17.59	17.69	17.79	17.89	
CERINTA DE APA	Q zi mediu	mc/zi	0.00	0.00	0.00	5.82	13.27	20.71	28.15	35.58	35.60	35.62	35.63	35.64	35.64	35.65	35.69	35.74	35.64	35.55	35.45	35.36	35.26	35.17	35.08	34.99	34.95	34.90	34.86	34.82	34.73			
	Q zi maxim	mc/zi	0.00	0.00	0.00	8.75	19.93	31.10	42.25	53.38	53.39	53.38	53.37	53.35	53.34	53.32	53.31	53.30	53.28	53.31	53.34	53.37	53.40	53.43	53.46	53.49	53.52	53.55	53.58	53.61	53.64	53.67	53.70	
	Q orar maxim	mc/h	0.00	0.00	0.00	1.01	2.29	3.58	4.86	6.13	6.13	6.13	6.12	6.12	6.11	6.11	6.10	6.10	6.09	6.09	6.09	6.06	6.03	6.01	5.98	5.95	5.93	5.93	5.89	5.85	5.83	5.80	5.78	

