

## Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Ticvanu-Cererea de apa

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043
Sistemul de alimentare cu apa TICVANIU MARE		Populatie totala in aria de deservire cap	1213	1202	1190	1179	1168	1157	1146	1135	1124	1113	1102	1092	1081	1070	1060	1049	1039	1029	1019	1004	989	974	960	946	932	919	905	892	879	866	853	841
		<b>CONSUM CASNIC</b>																																
RURAL		Total populatie rurala nr.	1213	1202	1190	1179	1168	1157	1146	1135	1124	1113	1102	1092	1081	1070	1060	1049	1039	1029	1019	1004	989	974	960	946	932	919	905	892	879	866	853	841
		Populatie rurala conectata nr.	776	831	884	936	988	1038	1087	1135	1124	1113	1102	1092	1081	1070	1060	1049	1039	1029	1019	1004	989	974	960	946	932	919	905	892	879	866	853	841
		Grad de bransare %	63.96	69.11	74.26	79.41	84.56	89.70	94.85	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Consum specific rural l/om.zi	66.41	66.30	66.20	66.36	66.37	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
		Qzi med rural l/s	0.60	0.64	0.68	0.72	0.77	0.81	0.86	0.90	0.90	0.90	0.89	0.89	0.88	0.88	0.88	0.88	0.87	0.87	0.86	0.85	0.85	0.84	0.83	0.82	0.81	0.81	0.80	0.80	0.80	0.79	0.79	0.79
		Qzi max rural l/s	0.95	1.01	1.08	1.14	1.22	1.29	1.36	1.43	1.43	1.43	1.42	1.42	1.41	1.41	1.41	1.40	1.40	1.39	1.39	1.38	1.37	1.36	1.35	1.34	1.33	1.32	1.31	1.30	1.29	1.28	1.27	1.26
		Qor max rural l/s	2.73	2.92	3.10	3.29	3.51	3.72	3.92	4.13	4.12	4.11	4.10	4.08	4.07	4.06	4.05	4.04	4.03	4.01	4.00	3.97	3.94	3.91	3.88	3.85	3.82	3.79	3.76	3.73	3.70	3.68	3.65	3.62
		<b>CONSUM NONCASNIC</b>																																
RURAL		Total bransamente nr.	0	0	0	11	11	12	12	12	12	12	12	13	13	13	13	13	13	13	13	14	14	14	14	14	14	14	14	15	15	15	15	
		Bransamente - Institutii nr.	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	
		Bransamente - Companii nr.	8	9	9	9	9	10	10	10	10	10	10	11	11	11	11	11	11	11	11	11	11	11	11	12	12	12	12	12	12	12	12	
		Grad de bransare %	82.58	85.07	87.56	90.04	92.53	95.02	97.51	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	
		Consum specific - INSTITUTII l/bransament.zi	1298.63	1292.14	1285.68	1279.25	1274.13	1269.03	1263.96	1258.90	1255.13	1251.36	1247.61	1243.86	1240.13	1236.41	1232.70	1229.00	1225.32	1221.64	1217.98	1214.32	1210.66	1207.05	1203.43	1199.82	1196.22	1192.63	1189.05	1185.48	1181.93	1178.38	1174.85	1171.32
		Qzi med rural l/s	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	
		Qzi max rural l/s	0.05	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.06	
		Qor max rural l/s	0.14	0.12	0.12	0.12	0.13	0.13	0.13	0.13	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16
		Consum specific - COMPANII l/bransament.zi	1079.45	1077.29	1075.14	1072.99	1070.86	1068.74	1066.62	1064.51	1062.41	1060.32	1058.24	1056.17	1054.11	1052.06	1050.01	1047.97	1045.94	1043.91	1041.89	1039.87	1037.86	1035.85	1033.84	1031.84	1029.84	1027.84	1025.84	1023.84	1021.84	1019.84	1017.84	
		Qzi med rural l/s	0.10	0.11	0.11	0.11	0.12	0.12	0.12	0.13	0.13	0.13	0.13	0.13	0.13	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
		Qzi max rural l/s	0.16	0.17	0.18	0.18	0.19	0.19	0.20	0.20	0.20	0.20	0.21	0.21	0.21	0.21	0.21	0.22	0.22	0.22	0.22	0.22	0.23	0.23	0.23	0.23	0.23	0.24	0.24	0.24	0.24	0.25	0.25	0.25
		Qor max rural l/s	0.46	0.49	0.50	0.52	0.53	0.55	0.56	0.58	0.58	0.59	0.60	0.61	0.61	0.62	0.62	0.63	0.63	0.63	0.64	0.65	0.65	0.66	0.66	0.67	0.67	0.68	0.69	0.70	0.71	0.71	0.71	0.71
TICVANIU MARE		Total general	1213	1202	1190	1179	1168	1157	1146	1135	1124	1113	1102	1092	1081	1070	1060	1049	1039	1029	1019	1004	989	974	960	946	932	919	905	892	879	866	853	841
		Ticvaniu Mare	845	837	829	821	814	806	798	791	783	776	768	760	753	745	738	731	724	717	710	699	689	679	669	659	649	640	630	621	612	603	594	586
		Ticvaniu Mic	368	365	361	358	354	351	348	344	341	338	334	331	328	325	322	318	315	312	309	305	300	296	291	287	283	279	275	271	267	263	259	255

CONSUMUL DE APA		Q zi mediu mc/zi	62.77	66.53	70.28	74.21	78.54	82.83	87.06	91.27	91.21	91.12	91.03	90.94	90.86	90.77	90.68	90.59	90.51	90.42	90.34	89.88	89.44	88.99	88.56	88.12	87.69	87.27	86.85	86.43	86.02	85.61	85.21	84.88
		Q zi maxim mc/zi	99.90	105.89	111.86	118.11	125.01	131.83	138.56	145.25	145.17	145.03	144.89	144.74	144.60	144.46	144.32	144.19	144.05	143.91	143.78	143.66	142.35	141.64	140.94	140.25	139.57	138.89	138.22	137.56	136.90	136.26	135.61	134.77
		Q orar maxim mc/h	11.98	12.70	13.42	14.17	14.99	15.81	16.62	17.42	17.41	17.40	17.38	17.36	17.34	17.33	17.31	17.29	17.28	17.26	17.25	17.16	17.07	16.99	16.91	16.82	16.74	16.66	16.58	16.50	16.42	16.34	16.27	16.17
		Q specific casnic l/om.zi	0.00	0.00	0.00	66.36	66.97	67.54	68.07	68.59	69.08	69.57	70.06	70.55	71.05	71.55	72.05	72.56	73.07	73.59	74.10	74.63	75.15	75.68	76.21	76.75	77.29	77.83	78.38	78.93	79.49	80.05	80.61	81.18
		Q specific noncasnic l/bransament.zi	0.00	0.00	0.00	1107.05	1107.10	1107.16	1107.22	1107.28	1107.34	1107.40	1107.46	1107.52	1107.58	1107.64	1107.70	1107.76	1107.82	1107.88	1107.94	1108.00	1108.06	1108.12	1108.18	1108.24	1108.30	1108.36	1108.42	1108.48	1108.54	1108.60	1108.66	1108.72
PIERDERI DE APA		mc/an	0.00	7892.85	8392.03	8918.19	9499.96	10082.84	10665.82	11252.46	11317.87	11378.38	11439.06	11497.88	11536.83	11585.90	11635.11	11684.45	11733.92	11784.39	11835.37	12017.73	12080.14	12142.61	12205.16	12267.78	12330.49	12393.30	12456.22	12519.90	12583.97	12648.42	12713.27	12778.51
		%	0.00	0.00	0.00	24.77	24.89	25.01	25.13	25.25	25.37	25.49	25.61	25.71	25.81	25.91	26.01	26.11	26.21	26.31	26.41	26.51	26.61	26.71	26.81	26.91	27.01	27.11	27.21	27.31	27.41	27.51	27.61	27.71
CERINTA DE APA		Q zi mediu mc/zi	62.77	88.15	93.27	98.64	104.57	110.45	116.28	122.09	122.22	122.30	122.37	122.42	122.46	122.51	122.56	122.61	122.65	122.69	122.73	122.77	122.81	122.85	122.89	122.93	122.97	123.01	123.05	123.09	123.13	123.17	123.21	123.25
		Q zi maxim mc/zi	99.90	127.51	134.85	142.54	151.03	159.45	167.78	176.08	176.23	176.28	176.33	176.38	176.43	176.48	176.53	176.58	176.63	176.68	176.73	176.78	176.83	176.88	176.93	176.98	177.03	177.08	177.13	177.18	177.23	177.28	177.33	177.38
		Q orar maxim mc/h	11.98	13.60	14.37	15.18	16.08	16.96	17.84	18.71	18.70	18.69	18.68	18.67	18.66	18.65	18.64	18.63	18.62	18.61	18.60	18.59	18.58	18.57	18.56	18.55	18.54	18.53	18.52	18.51	18.50	18.49	18.48	18.47

