

Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Anina-Colectare apa Uzata

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043		
Sistemul de Canalizare ANINA	Populatie totala in aria de deservire		cap	7485	7408	7332	7256	7181	7107	7034	6962	6890	6821	6753	6685	6618	6551	6486	6421	6357	6293	6230	6137	6046	5956	5868	5781	5695	5611	5527	5444	5363	5283	5204	5126	
	URBAN	CONSUM CASNIC		nr.	7485	7408	7332	7256	7181	7107	7034	6962	6890	6821	6753	6685	6618	6551	6486	6421	6357	6293	6230	6137	6046	5956	5868	5781	5695	5611	5527	5444	5363	5283	5204	5126
		Total populatie urbana		nr.	4525	5455	6366	7256	7181	7107	7034	6962	6890	6821	6753	6685	6618	6551	6486	6421	6357	6293	6230	6137	6046	5956	5868	5781	5695	5611	5527	5444	5363	5283	5204	5126
		Populatie urbana racordata		nr.	60.45	73.64	86.82	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
		Grad de racordare		%	79.01	73.99	77.97	81.95	82.79	83.49	84.96	84.79	85.31	85.91	86.52	87.13	87.74	88.35	88.96	89.57	90.18	90.79	91.40	92.01	92.62	93.23	93.84	94.45	95.06	95.67	96.28	96.89	97.50	98.11	98.72	99.33
	Consum specific urban		l/om.zi	3.67	4.67	5.74	6.88	6.87	6.86	6.84	6.83	6.80	6.78	6.76	6.74	6.72	6.70	6.68	6.66	6.64	6.62	6.60	6.58	6.56	6.54	6.52	6.50	6.48	6.46	6.44	6.42	6.40	6.38	6.36	6.34	
	Qzi med urban		l/s	4.93	6.28	7.73	9.26	9.24	9.23	9.20	9.18	9.15	9.12	9.09	9.07	9.04	9.01	8.98	8.96	8.93	8.90	8.87	8.84	8.81	8.78	8.75	8.72	8.69	8.66	8.63	8.60	8.57	8.54	8.51	8.48	
	Qzi max urban		l/s	12.27	15.63	19.22	23.03	23.00	22.95	22.89	22.83	22.76	22.69	22.62	22.55	22.48	22.41	22.35	22.28	22.21	22.14	22.08	22.01	21.94	21.87	21.80	21.73	21.66	21.59	21.52	21.45	21.38	21.31	21.24	21.17	
	Qzi orar maxim		l/s	12.27	15.63	19.22	23.03	23.00	22.95	22.89	22.83	22.76	22.69	22.62	22.55	22.48	22.41	22.35	22.28	22.21	22.14	22.08	22.01	21.94	21.87	21.80	21.73	21.66	21.59	21.52	21.45	21.38	21.31	21.24	21.17	
	URBAN	CONSUM NONCASNIC		nr.	75	78	80	83	83	83	83	83	83	83	84	84	85	85	85	85	86	86	86	87	87	87	87	88	88	88	89	89	89	89	89	
Total racorduri		nr.	75	78	80	83	83	83	83	83	83	83	84	84	85	85	85	85	86	86	86	87	87	87	87	88	88	88	89	89	89	89	89			
Racorduri - instituti		nr.	28	28	28	28	28	28	28	29	29	29	29	29	29	29	29	29	29	29	30	30	30	30	30	30	30	30	30	30	30	30	30			
Racorduri - Companii		nr.	47	50	52	55	55	55	55	54	54	54	55	55	56	56	56	56	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57			
Grad de racordare		%	90.88	93.92	96.85	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00		
Consum specific - INSTITUTII		l/racord.zi	2436.47	2567.53	2696.90	2825.97	2814.86	2803.40	2792.19	2781.02	2772.66	2764.36	2756.07	2747.80	2739.56	2731.34	2723.14	2714.97	2706.83	2698.71	2690.61	2682.54	2674.49	2666.47	2658.47	2650.49	2642.54	2634.62	2626.71	2618.83	2610.97	2603.14	2595.33	2587.55		
Qzi med urban		l/s	0.79	0.83	0.88	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92		
Qzi max urban		l/s	1.06	1.12	1.18	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24		
Qor max urban		l/s	2.64	2.79	2.94	3.09	3.09	3.09	3.09	3.09	3.08	3.08	3.08	3.08	3.08	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	3.09	
Consum specific - COMPANII		l/racord.zi	1758.30	1786.01	1801.72	1823.43	1825.25	1827.08	1828.90	1830.73	1832.56	1834.39	1836.22	1838.05	1839.88	1841.71	1843.54	1845.37	1847.20	1849.03	1850.86	1852.69	1854.52	1856.35	1858.18	1860.01	1861.84	1863.67	1865.50	1867.33	1869.16	1871.00	1872.83	1874.66		
Qzi med urban		l/s	0.96	1.02	1.08	1.15	1.15	1.15	1.15	1.15	1.15	1.16	1.16	1.17	1.17	1.18	1.18	1.19	1.19	1.20	1.20	1.21	1.21	1.22	1.22	1.23	1.23	1.24	1.24	1.25	1.25	1.26	1.27	1.27		
Qzi max urban		l/s	1.29	1.37	1.45	1.54	1.54	1.54	1.54	1.55	1.55	1.56	1.57	1.57	1.58	1.59	1.59	1.60	1.61	1.62	1.63	1.64	1.65	1.66	1.67	1.68	1.69	1.70	1.70	1.71	1.72	1.73	1.74	1.75		
Qor max urban		l/s	3.20	3.41	3.62	3.83	3.83	3.84	3.84	3.84	3.85	3.86	3.86	3.87	3.88	3.89	3.90	3.91	3.92	3.93	3.94	3.95	3.96	3.97	3.98	3.99	4.00	4.01	4.02	4.03	4.04	4.05	4.06	4.07	4.08	
ANINA	Total general		7485	7408	7332	7256	7181	7107	7034	6962	6890	6821	6753	6685	6618	6551	6486	6421	6357	6293	6230	6137	6046	5956	5868	5781	5695	5611	5527	5444	5363	5283	5204	5126		
	Anina		5506	5449	5393	5337	5282	5228	5174	5121	5068	5017	4967	4917	4868	4819	4771	4723	4676	4629	4583	4537	4491	4448	4406	4364	4322	4281	4240	4200	4160	4120	4080	4040	4000	
	Steierdorf		1979	1959	1939	1919	1899	1879	1860	1841	1822	1804	1786	1768	1750	1732	1715	1698	1681	1664	1647	1630	1613	1596	1579	1562	1545	1528	1511	1494	1477	1460	1443	1426	1409	1392

TOTAL APA UZATA COLECTATA		mc/zi	467.69	563.70	665.72	773.48	772.74	771.63	770.18	768.65	767.19	765.84	764.52	763.15	761.81	760.42	759.15	757.83	756.55	755.21	753.91	749.79	745.77	741.75	737.82	733.91	730.00	726.19	722.30	718.41	714.64	710.88	707.13	703.39
Q zi maxim		mc/h	629.04	758.16	895.38	1040.32	1039.31	1037.83	1035.87	1033.81	1031.85	1030.04	1028.27	1026.42	1024.62	1022.75	1021.04	1019.27	1017.54	1015.74	1013.99	1008.45	1003.04	997.63	992.36	987.09	981.83	976.71	971.47	966.25	961.07	955.11	951.07	945.38
Q orar maxim		mc/h	65.19	78.58	92.80	107.82	107.72	107.56	107.36	107.15	106.94	106.75	106.57	106.38	106.19	106.00	105.82	105.64	105.46	105.27	105.09	104.52	103.96	103.40	102.85	102.30	101.76	101.23	100.68	100.14	99.62	99.09	98.57	97.98
Q specific casnic		l/om.zi	70.01	69.89	69.78	69.96	70.60	71.19	71.75	72.30	72.82	73.34	73.85	74.37	74.90	75.42	75.96	76.49	77.03	77.57	78.12	78.67	79.22	79.78	80.34	80.91	81.47	82.05	82.62	83.20	83.79	84.38	84.97	85.57
Q specific noncasnic		l/racord.zi	2012.23	2065.45	2116.93	2166.84	2164.87	2162.91	2160.93	2158.96	2157.24	2155.53	2153.83	2152.14	2150.47	2148.80	2147.15	2145.50	2143.87	2142.24	2140.63	2139.03	2137.44	2135.85	2134.28	2132.72	2131.17	2129.63	2128.09	2126.58	2125.07	2123.57	2122.08	2120.61
INFILTRATI		mc/an	196351.18	183261.11	170717.03	157080.95	157641.95	158202.95	158763.96	159324.96	159885.96	160446.97	161007.97	161568.98	162129.98	162690.98	163251.99	163812.99	164373.99	164935.00	165496.00	166057.00	166618.01	167179.01	167740.01	168301.02	168862.02	169423.02	169984.03	170545.03	171106.03	171667.04	172228.04	172789.04
Q zi mediu		mc/zi	53.49	47.11	41.19	35.75	35.85	35.97	36.09	36.22	36.35	36.47	36.59	36.71	36.83	36.95	37.07	37.19	37.31	37.44	37.56	37.68	37.80	37.92	38.04	38.16	38.28	38.40	38.52	38.64	38.76	38.88	39.00	39.12
Q zi maxim		mc/zi	1005.64	1065.78	1131.94	1203.84	1204.63	1205.07	1205.15	1205.16	1205.24	1205.42	1205.64	1205.81	1206.01	1206.15	1206.42	1206.63	1206.89	1207.09	1207.32	1207.44	1207.56	1207.68	1207.80	1207.92	1208.04	1208.16	1208.28	1208.40	1208.52	1208.64	1208.76	1208.88
Q orar maxim		mc/h	1166.98	1260.24	1361.60	1470.68	1471.21	1471.26	1470.84	1470.32	1469.90	1469.62	1469.38	1469.08	1468.81	1468.48	1468.31	1468.07	1467.88	1467.64	1467.40	1467.16	1466.92	1466.68	1466.44	1466.20	1465.96	1465.72	1465.48	1465.24	1465.00	1464.76	1464.52	1464.28
Q orar maxim		mc/h	87.61	99.50	112.22	125.75	125.71																											