

# Actualizare Master Plan si Program de investitii Prioritare(2013-2018)-Aglomerare Baile Herculane-Colectare apa Uzata

An		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043			
Sistemul de Canalizare BAILE HERCULANE	Populatie totala in aria de deservire		5008	4956	4905	4855	4805	4756	4707	4658	4610	4564	4518	4472	4427	4382	4338	4295	4252	4210	4168	4106	4045	3985	3926	3868	3810	3753	3697	3642	3587	3533	3481	3430			
	CONSUM CASNIC		nr.	5008	4956	4905	4855	4805	4756	4707	4658	4610	4564	4518	4472	4427	4382	4338	4295	4252	4210	4168	4106	4045	3985	3926	3868	3810	3753	3697	3642	3587	3533	3481	3430		
	URBAN	Total populatie urbana	nr.	3310	3836	4351	4855	4805	4756	4707	4658	4610	4564	4518	4472	4427	4382	4338	4295	4252	4210	4168	4106	4045	3985	3926	3868	3810	3753	3697	3642	3587	3533	3481	3430		
		Populatie urbana racordata	nr.	66.10	77.40	88.70	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	
		Grad de racordare	%	66.10	77.40	88.70	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	
		Consum specific urban	l/om.zi	82.02	82.33	82.64	82.95	83.27	84.42	85.08	85.73	86.35	86.98	87.57	88.18	88.81	89.43	90.06	90.69	91.33	91.98	92.62	93.28	93.93	94.59	95.26	95.93	96.61	97.29	97.97	98.66	99.35	100.05	100.76	101.47		
		Qzi med urban	l/s	3.14	3.66	4.16	4.66	4.66	4.65	4.63	4.62	4.61	4.59	4.58	4.56	4.55	4.54	4.51	4.49	4.48	4.47	4.43	4.40	4.36	4.33	4.29	4.26	4.23	4.19	4.16	4.12	4.09	4.06	4.03	4.00		
		Qzi max urban	l/s	4.22	4.91	5.59	6.26	6.25	6.24	6.22	6.20	6.19	6.17	6.15	6.13	6.11	6.09	6.07	6.05	6.03	6.02	6.00	5.95	5.90	5.86	5.81	5.77	5.72	5.67	5.63	5.58	5.54	5.49	5.45	5.41		
		Qor max urban	l/s	11.21	13.04	14.84	16.63	16.60	16.57	16.53	16.49	16.43	16.38	16.33	16.28	16.23	16.18	16.13	16.08	16.03	15.99	15.94	15.81	15.69	15.56	15.44	15.32	15.20	15.07	14.95	14.83	14.71	14.59	14.48	14.37		
		CONSUM NONCASNIC																																			
		URBAN	Total racorduri	nr.	137	143	148	154	154	155	155	156	156	157	157	158	158	159	159	160	160	161	161	162	162	163	163	164	164	165	165	166	166	167	167	167	
			Racorduri - Institutii	nr.	12	12	12	12	12	12	12	12	12	12	12	12	12	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	
	Racorduri - Companii		nr.	125	130	136	141	142	142	143	143	144	144	145	145	146	146	147	147	148	148	148	148	149	149	150	150	151	151	152	152	153	153	154	154	154	
	Grad de racordare		%	90.13	92.82	96.09	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	
	Consum specific - INSTITUTII		l/racord.zi	2390.12	4016.61	5733.09	7449.57	7419.77	7390.09	7360.53	7331.09	7309.09	7287.17	7265.31	7243.51	7221.78	7200.11	7178.51	7156.98	7135.51	7114.10	7092.76	7071.48	7050.27	7029.12	7008.03	6987.00	6966.04	6945.14	6924.31	6903.54	6882.83	6862.18	6841.59	6821.07		
	Qzi med urban		l/s	0.32	0.56	0.80	1.05	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.04	1.05	1.05	1.05	1.05	1.04		
	Qzi max urban		l/s	0.43	0.75	1.08	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40		
	Qor max urban		l/s	1.14	2.00	2.86	3.73	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.72	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.73	3.72	
	Consum specific - COMPANII		l/racord.zi	5133.70	4997.49	4861.28	4725.07	4729.79	4734.52	4735.26	4744.00	4748.74	4753.49	4758.24	4763.00	4767.76	4772.53	4777.30	4782.06	4786.82	4791.58	4796.34	4801.10	4805.86	4810.62	4815.38	4820.14	4824.90	4829.66	4834.42	4839.18	4843.94	4848.70	4853.46	4858.22		
	Qzi med urban		l/s	7.43	7.55	7.65	7.73	7.77	7.80	7.83	7.87	7.90	7.94	7.97	8.00	8.04	8.07	8.10	8.14	8.17	8.21	8.24	8.28	8.31	8.34	8.38	8.41	8.45	8.48	8.52	8.55	8.59	8.62	8.66	8.66		
	Qzi max urban	l/s	9.97	10.13	10.27	10.38	10.43	10.47	10.52	10.56	10.61	10.65	10.70	10.74	10.79	10.83	10.88	10.93	10.97	11.02	11.06	11.11	11.16	11.20	11.25	11.30	11.34	11.39	11.44	11.48	11.53	11.58	11.62	11.63			
	Qor max urban	l/s	26.49	26.92	27.28	27.59	27.70	27.82	27.94	28.06	28.18	28.30	28.43	28.55	28.67	28.79	28.91	29.03	29.15	29.28	29.40	29.52	29.64	29.77	29.89	30.01	30.14	30.26	30.38	30.51	30.63	30.76	30.88	30.89			
	Total general		5008	4956	4905	4855	4805	4756	4707	4658	4610	4564	4518	4472	4427	4382	4338	4295	4252	4210	4168	4106	4045	3985	3926	3868	3810	3753	3697	3642	3587	3533	3481	3430			
	BAILE HERCULANE	Baile Herculane	4490	89.65	4490	4443	4397	4352	4307	4263	4219	4175	4132	4091	4050	4009	3969	3929	3890	3851	3812	3774	3736	3698	3660	3622	3584	3546	3508	3470	3432	3394	3356	3318			
Pecinisca		518	10.35	518	513	508	503	498	493	488	483	478	473	468	463	458	453	448	444	440	436	432	428	424	420	416	412	408	404	400	396	392	388	384			

TOTAL APA UZATA COLECTATA		UM	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	
TOTAL APA UZATA COLECTATA	Q zi mediu	mc/zi	940.84	1016.20	1089.65	1161.18	1163.49	1165.60	1167.41	1169.13	1170.79	1172.53	1174.24	1175.92	1177.65	1179.34	1181.00	1182.91	1184.70	1186.54	1188.35	1188.27	1188.22	1188.21	1188.24	1188.30	1188.32	1188.37	1188.46	1188.60	1188.69	1188.82	1189.10	1189.38	
	Q zi maxim	mc/zi	1263.06	1364.24	1462.83	1558.87	1561.97	1564.80	1567.23	1569.54	1571.77	1574.11	1576.40	1578.65	1580.97	1583.25	1585.61	1588.05	1590.44	1592.91	1595.35	1595.23	1595.17	1595.15	1595.19	1595.28	1595.30	1595.37	1595.50	1595.68	1595.80	1595.97	1596.35	1596.70	
	Q orar maxim	mc/h	139.83	151.03	161.95	172.52	173.24	173.76	174.01	174.27	174.52	174.77	175.03	175.28	175.54	175.81	176.07	176.35	176.62	176.91	177.20	177.50	177.80	178.10	178.40	178.70	179.00	179.30	179.60	179.90	180.20	180.50	180.80	181.10	181.40
	Q specific casnic	l/om.zi	82.02	81.89	81.76	81.97	82.72	83.42	84.07	84.72	85.33	85.93	86.53	87.14	87.76	88.37	88.99	89.62	90.25	90.89	91.53	92.17	92.82	93.47	94.13	94.80	95.46	96.13	96.81	97.49	98.18	98.87	99.56	100.26	
Q specific noncasnic	l/bransament.zi	4885.50	4914.62	4932.43	4940.15	4942.14	4944.15	4946.17	4948.21	4950.24	4952.26	4954.29	4956.32	4958.35	4960.38	4962.41	4964.44	4966.47	4968.50	4970.53	4972.56	4974.59	4976.62	4978.65	4980.68	4982.71	4984.74	4986.77	4988.80	4990.83	4992.86	4994.89	4996.92	4998.95	
INFILTRATI																																			
APA UZATA INFLUENTA IN STATIA DE EPURARE	Q zi mediu	mc/zi	2010.13	2052.91	2093.77	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	2132.71	
	Q zi maxim	mc/zi	2332.35	2400.95	2466.95	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40	2530.40
	Q orar maxim	mc/h	184.39	194.23	203.79	213.06	208.58	204.06	199.50	194.93	195.31	195.70	196.09	196.47	196.86	197.24	197.64	198.04	198.44	198.84	199.24	199.64	199.99	200.39	200.79	201.19	201.59	201.99	202.39	202.79	203.19	203.59	203.99	204.39	204.79