

REZULTATUL ANALIZEI APEI POTABILE DIN ORAȘUL BOCȘA - LUNA MAI 2023

Data prelevării		10.05.2023		24.05.2023	
Parametru determinat	UM	Sediul Aquacaraș	Bazin Tata Oancea	SC Doly SA	Liceul Tata Oancea
Turbiditate*	NTU	0,86	0,76	0,54	0,65
Culoare*	mgPt,Co/l	<1	<1	<1	<1
pH*	Unit.pH	6,74	7,83	6,79	7,81
Conductivitate*	μS/cm	294	557	324	575
Indice de permanganat	mgO ₂ /l	<1,00	<1,00	<1,00	<1,00
Clor rezidual liber	mg/l	1,14	0,43	1,35	0,33
Clor rezidual total	mg/l	1,21	0,48	1,41	0,42
Dioxid de clor	mg/l	-	-	-	-
Amoniu	mgNH ₄ ⁺ /l	<0,032	<0,032	<0,032	<0,032
Nitriti	mgNO ₂ ⁻ /l	<0,020	<0,020	<0,020	<0,020
Nitrati	mgNO ₃ ⁻ /l	2,83	3,23	-	-
Duritate	^o d	7,29	17,05	-	-
Aluminiu solubil	μg/l	-	-	-	-
Fier total	μg/l	<30	<30	<30	<30
Gust*	-	3	1	3	1
Miros*	-	3	1	3	1
Bacterii coliforme	Nr. ufc /100ml	0	0	0	0
Enterococi intestinali	Nr. ufc /100ml	0	0	0	0
Escherichia coli	Nr. ufc /100ml	0	0	0	0
Clostridium perfringens	Nr. ufc /100ml	-	0	-	-